

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/EH/2019/WZ/ 836

Dated: 16/4 /2019

FIRE SAFETY CERTIFICATE

Certified that the **M/s World Art Dining** (a Unit of Nimitaya Hospitality LLP) located at premises No. 1, 3rd Floor, Main Club Road, Punjabi Bagh, New Delhi in a building comprised of B+G+04 Uppers Floors was issued FSC vide Letter No. F6/DFS/MS/EH/2015/WZ/2000 dated 06/11/2015. The premises was re inspected by the officers concerned of this department on 26-03-2019 in the presence of Mr. Gurdeep Singh and found that the said building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D with effect from 16/4/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on16/4/19..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,

Copy to:

1. M/s World Art Dining (a unit of Nimitaya Hospitality LLP) situated at premises No. 1, 3rd Floor, Main Club Road, Punjabi Bagh, New Delhi
2. The Dy. Health Officer, Health Department, West Zone, Rajouri Garden, New Delhi

Following fire safety directives must be adhered to:-

1. **The FSC is valid for 3rd Floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building bye laws.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : M/s World Art Dining (a unit of Nimitaya Hospitality LLP) situated at premises No. 1, 3rd Floor, Main Club Road, Punjabi Bagh, New Delhi
2. Type of Occupancy : Assembly (B+G+04 upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2015/WZ/2000 dated 06/11/2015
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 26-03-2019
7. Name of the Inspecting Officers : Mukesh Verma DO (West.)
8. Name and designation of officers
- From the building side : Mr. Gurdeep Singh
9. Year of Construction : 2005-2006 (As per N-I)
10. Applicant's letter No. : DFS out dairy no. 5447 dated 13/03/2019

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 m	Provided	M/R
		4.5 mtr	Provided	M/R
	• Gate width	N.R.	N.R.	N.R.
	• Width of internal road			
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	M.R.
	• Basement	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mtr & 1 mtr	135 & 1 mtr (iron)	MR (Being old case)
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	N.R.	N.R.	N.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	Required	1 provided	M.R.
	e. Width of Corridor	NA	NA	NA
	f. Door size	2 mtr	153 cm & 1 mtr	MR (Being old case)
3.	Compartmentation.			
	• Fire check door	N.R.	N.R.	N.R.
	• Sealing of electrical shafts	N.R.	N.R.	N.R.
	• Fire Rating of shaft door	N.R.	N.R.	N.R.
	• Water Curtain	N.R.	N.R.	N.R.
	• Fire Dampers	N.R.	N.R.	N.R.
4.	Smoke Management System.			
	• Basements	N.A.	N.A.	N.A.
	• Upper floors	Required	Provided	M.R.

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 CO ₂ , & ABC type ISI marked	06 Provided Provided Provided	M.R M.R M.R
6.	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m required 5 mm	Provided Provided Provided	M.R M.R M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 	Required Required Required Required Required	Provided Provided Provided Provided Provided	M.R M.R M.R M.R M.R
8.	MOEFA	Required	Provided	M.R
9.	Public Address System	N.R.	N.R.	N.R.
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N.A. N.R. N.R.	N.A. Provided N.R.	N.A. N.R. N.R.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 m. m 01 01	Found Provided Found Provided Found Provided	M.R M.R M.R
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N.R. N.R.	N.R. N.R.	N.R. N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
	Terrace level			
	➤ Discharge of pump	900 LPM	Found Provided	M.R
	➤ Head of the pump	60 mtr	Found Provided	M.R

	➤ Power supply	required	Found Provided	M.R
	➤ Auto Starting of pump	required	Found Provided	M.R
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	N.A	N.A.	N.A.
	➤ Draw -off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	➤ Overhead Tank Capacity	10,000 ltrs	Found Provided	M.R
15	Exit Signage.	required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N.R	N.R	N.R
	➤ Location	N.R	N.R	N.R
19.	Fire Control Room			
	➤ Detector System Panel	N.R	N.R	N.R
	➤ Flow Switch Panel	N.R	N.R	N.R
	➤ PA system Panel	N.R	N.R	N.R
	➤ Batter backup	N.R	N.R	N.R
	➤ Building Floor plans	N.R	N.R	N.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.R	N.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2015/WZ/2000 dated 06/11/2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name Mukesh Verma

Designation DO (West)

Mukesh Verma
15/11/19

[Signature]
15/11/19