

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/EH/2019/SZ/ 958

Dated: 8/5/19

FIRE SAFETY CERTIFICATE

Certified that the **Burger King India Pvt. Ltd.**, Unit No.-GF-05, Orchard Road, Janak Puri West Metro Station, New Delhi-110058, two Basements, Ground plus eight upper floors & terrace but restaurant is at ground floor only, was issued FSC by this department vide letter no. F6/DFS/MS/EH/2015/SZ/2016 dated 09.11.2015 owned/occupied by Burger King India Pvt. Ltd. The restaurant building was re-inspected by the officers concerned of this department on 10.04.2019 in the presence of Sh. Daya Sagar (Store Manager) and found that Management of Burger King India Pvt. Ltd have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground Floor Only**) is fit for occupancy class Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....8/5/19..... at New Delhi.

(ATUL GARG)  
CHIEF FIRE OFFICER

Copy to:-

1. The Manager,  
Burger King India Pvt. Ltd., Unit No.-GF-05,  
Orchard Road, Janak Puri West Metro Station, New Delhi-110058
2. The Dy. Health Officer,  
S.D.M.C, Public Health Department, West Zone,  
Vishal Enclave, Rajouri Garden, New Delhi-110027

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : Burger King India Pvt. Ltd., Unit No.-GF-05, Orchard Road, Janak Puri West Metro Station, New Delhi-110058.
2. Type of Occupancy : Group D (Assembly)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2015/SZ/2016 dated 09.11.2015
5. Fire Safety directives letter No : F6/MS/DFS/MS/BP/2014/207 dated 28.07.2014 (for whole bldg.)
6. Date of inspection : 10.04.2019
7. Name of Inspecting Officers : D.O. M.K. Chattopadhyay & A.D.O. Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh. Daya Sagar (Store Manager)
9. Year of Construction : 2015
10. Applicant's letter No. : Nil dated 22.11.2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	09 mtrs. 06 mtrs. 06 mtrs.	Provided Provided Provided	M/R M/R M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
			<b>(Restaurant at GF only)</b>	
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	03 No's	03 No's	M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	150 cms each 150 cms each	150 cms (03 no's) 150 cms (03 no's)	M/R M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required Required	Provided Provided	M/R M/R
	d. No. of continuous staircases to terrace			
		Required 150 cms	Provided Opening in hall	M/R M/R
	e. Width of Corridor			
	f. Door Size	200 cms & 100 cms	Provided	M/R
3.	<b>Compartmentation</b>			
			<b>(Restaurant at GF only)</b>	
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required Required 02 hrs Required Required	Provided Sealed Provided Provided Provided	M/R M/R M/R M/R M/R
4.	<b>Smoke Management System</b>			
			<b>(Restaurant at GF only)</b>	
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	Required Required	Provided Provided	M/R M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers in restaurant</li> <li>• Types</li> <li>• IS marking</li> </ul>	05 no.'s ABC/CO <sub>2</sub> ISI marked	Provided Provided Provided	M/R M/R M/R
6.	<b>First-Aid Hose Reels</b>			
			<b>(Common with parking cum commercial building)</b>	
	<ul style="list-style-type: none"> <li>• Total numbers for restaurant</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	One 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R

11/6

Building comprised of two Basements, Ground plus eight upper floors & terrace but restaurant is at ground floor.

<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors Smoke/Heat/Gas</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required	Provided	M/R
		Required	Provided at GF	M/R
		N/A	N/A	N/A
		Required	Provided	M/R
		Required	Near exit	M/R
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M/R
<b>9.</b>	<b>Public Address System</b>	Required	Provided	M/R
<b>10.</b>	<b>Automatic Sprinkler System (Restaurant at GF only)</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Ground Floor</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	M/R
<b>11.</b>	<b>Internal Hydrants (Common with parking cum commercial building)</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	150/100 mm	Provided	M/R
	<ul style="list-style-type: none"> <li>Number of hydrants for restaurant</li> </ul>	One	Provided	M/R
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	One	Provided	M/R
<b>12.</b>	<b>Yard Hydrants For entire building (Common with parking cum commercial building)</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	Seven	Provided	M/R
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	Seven	Provided	M/R
<b>13.</b>	<b>Pumping Arrangements For entire building (Common with parking cum commercial building)</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> </ul> </li> </ul>	2850 LPM	Provided	M/R
		90 mtrs	Provided	M/R
		Two	Provided	M/R
		280 LPM	Provided	M/R
		90 mtrs	Provided	M/R
	<ul style="list-style-type: none"> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Water curtain Pump</li> <li>Auto Starting/Manual Stopping</li> </ul>	2850 LPM	Provided	M/R
		90 mtrs	Provided	M/R
		1000 LPM	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>			
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	900 LPM	Provided	M/R
		40 mtrs	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
<b>14.</b>	<b>Captive Water Storage for fire fighting (Common with parking cum commercial building)</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	2,00,000 ltrs	Provided	M/R
	<ul style="list-style-type: none"> <li>Draw-off connection</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Fire service inlet</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Access to tank</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	20000 ltrs	Provided	M/R
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	M/R
<b>16.</b>	<b>Provision of Lifts. (Restaurant at GF only)</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Communication In lift Car</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	Required	Provided	M/R
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	M/R

NH

Building comprised of two Basements, Ground plus eight upper floors & terrace but restaurant is at ground floor.

19.	<b>Fire Control Room</b>	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	Required	Provided	M/R
			Required	Provided	M/R
			Required	Provided	M/R
			Required	Provided	M/R
			Required	Provided	M/R
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>		Required	Provided	M/R

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the fire safety certificate issued vide letter no. F6/DFS/MS/EH/2015/SZ/2016 dated 09.11.2015 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- The restaurant is at ground floor level in the Multi Level Car Parking cum Commercial area, Janak Puri West Metro Station, New Delhi and have common fire safety installations. The FSC was issued to Multi Level Car Parking cum Commercial area vide letter no. F.6/DFS/MS/PRKG/2019/SZ/173 dated 24.01.2019.

*[Signature]*  
23/4/19

Signature of Inspecting Officer  
Name:- M.K. Chattopadhyay  
Designation:- Divisional Officer

*[Signature]*  
23/4/19

Signature of Inspecting Officer  
Name:- Sandeep Duggal  
Designation:- Asstt. Divisional Officer



Dy.C.F.O.( South Zone)

*[Signature]*

*[Signature]*  
23/4/19

*[Signature]*  
DU/SRA

P.T. letter is put up for signature please.

*[Signature]*  
23/5/19

