GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2019/SZ/ 969 Dated: ...9/5/19

FIRE SAFETY CERTIFICATE

Certified that the Anand Vidya Bharti Education Society School located at F–II/476, Sangam Vihar, New Delhi-110062, comprised of two blocks- One block: basement (sealed), ground plus two upper floors, Second block- ground plus two upper floors, both interconnected with each other was issued NOC by this department vide letter No. F6/DFS/MS/School/2010/SZ/229 dated 07/09/2010. The premises was re-inspected by officer concerned of this department on 24/04/2019 in the presence of Mrs. Soni Chambial (Manager) of the school and found that school building have complied with the fire prevention and fire safety arrangements in accordance with Circular No. 262-362 dated 17/01/2005 issued by Education Directorate, Govt. of NCT of Delhi, Old Secretariat, New Delhi and that the premises is fit for occupancy class "Educational Building, Group-B" with effect from the date of issue of this certificate for a period of **Three years** subject to compliance of the conditions mentioned below.

Issued on 9/5/19 at New Delhi by

(Rajesh Panwar)
Dy. Chief Fire Officer
Ph: 011-26189168

Copy to: -

1. The Principal, Anand Vidya Bharti Education Society School located at F–II/476, Sangam Vihar, New Delhi-110062
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

N/3

INSPECTION REPORT				
1	Name & Address of the Building	Annand Vidya Bharti Education Society School, F-II/476,Sangam Vihar, New Delhi-110062		
2	Type of Occupancy	Educational "Group-B" (School)		
3	Building Comprised of	Comprised of two blocks- One block-basement-(sealed), ground plus two, second block-ground plus two upper floors both are interconnect with each other's.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2010/2593 Dated 07/09/2010		
6	Fire Safety Directives Letter No	DOE Circular 262-232 dated 17/01/2005		
7	Date of Inspection	24-04-2019		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mrs. Soni Chambial (Manager)		
10	Year of construction	2001		
11	Applicant letter No.	Nil dated 26/02/2019		
S. No	**Minimum standards on Fire Prevention and Fire Safety U/R 33**	**As Per Old NOC**	**Provided at Site**	**Remarks MR/NMR**
1	**Access to Building.**			
	• Road width	Required	Accessible	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	**Number, width, type & arrangement of exits**			
	a) Number of Staircase			
	➢ Upper floors	02 Nos	03 Nos	MR
	➢ Basement floor	N/A	N/A	N/A
	b) Width of Staircase			
	➢ Upper floors	1.5 m/0.75m	1.07m,1.03m & 0.93m	MR
	➢ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➢ Fire check door	N/A	N/A	N/A
	➢ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	One	Two	MR
	e) Width of corridor	1.5 mtr	Provided	MR
	f) Door size	1 mtr	1mtr	MR
3	**Compartmentation.**			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	NA	NA	NA
4.	**Smoke Management system.**			
	• Basement	30 ACPH	NA	MR
	• Upper floors	12 ACPH	N/A	N/A

N/A

5.	**Fire Extinguishers.**			
	• Total numbers	08 No's	09 No's	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	**First Aid Hose Reels.**			
	Total numbers on each floor.	One	Provided	MR
	Length of hose-reel hose.	30m	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	**Automatic fire detection & alarming system**			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	**MOEFA**	N/A	N/A	N/A
9.	**Public Address System**	N/A	N/A	N/A
10.	**Automatic Sprinkler System**			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants.**			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	**Yard Hydrants.**			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	**Pumping arrangements.**			
	• **Ground Level**			
	➢ Discharge of main pump.	N/A	N/A	N/A
	➢ Head of main pump.	N/A	N/A	N/A
	➢ Number of main pumps.	N/A	N/A	N/A
	➢ Jockey Pump output.	N/A	N/A	N/A
	➢ Jockey Pump head.	N/A	N/A	N/A
	➢ Standby Pump output.	N/A	N/A	N/A
	➢ Standby pump head.	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	• **Terrace Level**			
	➢ Discharge of pump.	225 LPM	Provided	MR
	➢ Head of pump.	30 m	30 m	MR
	➢ Power supply.	Required	Provided	MR
	➢ Auto starting of pump.	Required	Provided	MR

N/S

14.	**Captive water storage for Fire Fighting.**			
	• Underground tank capacity.	N/A	N/A	N/A
	➢ Draw-off connection.	N/A	N/A	N/A
	➢ Fire Service Inlet.	N/A	N/A	N/A
	➢ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 Litr	Provided	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provisions of Lifts.**			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	**Standby Power Supply**	N/A	N/A	N/A
18.	**Refuge Area**			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	**Fire Control Room.**			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	**Special Fire Protection System for the Protection of special Risk, if any.**			N/A

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No. F6/DFS/MS/2010/2593 Dated 07/09/2010, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.

Mehmood 29/4/19

Signature of the Inspecting Officer
Name: Mehmood
Designation: ADO (SJ)

FIRE SERVICE 30/4/19 1825 Dy. Chief Fire Officer

DO (SD)

30/4/19

Dy. CFO (S2)