

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. DFS/MS/Banquets/2019/ WZ/ 10535

Dated: 20/05/2019

FIRE SAFETY CERTIFICATE

Certified that the Euphoria Banquets (A Unit of Unicorn Celebrators) located at Plot No. F-3, Udyog Nagar, Delhi- 110041, is **running on Ground Floor, 1st Floor & 2nd Floor only** in a building comprising Two Basements, Ground Floor, Mezzanine Floor, 1st Floor & 2nd Floor only owned / occupied by Euphoria Banquets (A Unit of Unicorn Celebrators), have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules 2010 and verified by the officer concerned of Fire Service on 08.05.2019 in presence of Sh. Gopal Kumar (Partner) and that the building / premises is fit for occupancy class Assembly (Group – D) / Banquets with effect from 20 / 05 /2019 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 20/05/19 at New Delhi.

(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to :-

1. Sh. Gopal Kumar (Partner), Euphoria Banquets (A Unit of Unicorn Celebrators), Plot No. F-3, Udyog Nagar, Delhi- 110041.
2. Deputy Health Officer, Rohini Zone, North Delhi Municipal Corporation, Public Health Department, Sec.-5, Rohini, New Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. Basements shall be used strictly as per Building-By-Laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this fire safety certificate to the Director in Form 'J' (sub rule (1) of rule 37 alongwith a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Euphoria Banquets (A Unit of Unicorn Celebrators)
Plot No. F-3, Udyog Nagar, Delhi- 110041.
2. Type of Occupancy : Assembly (Banquet Hall)
3. Type of Case : New
4. Details of previous NOC : Nil

Two Basements + Ground Floor, Mezz. Floor, 1 st Floor & 2 nd Floor only

5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2019/784 dated 08/02/2019
6. Date of inspection : 08/05/2019
7. Name of the Inspecting Officer : A. K.-Jaiswal A.D.O. (Jwp.)
8. Name and designation of Officer
from the building side : Sh. Gopal Kumar
9. Year of Construction : 2017-18
10. Applicant's letter No. : - Nil out door diary no. 6766 dated 25/03/19

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	18 mtr.	20 mtr.	MR
	• Gate width	4.5 mtr.	Provided	MR
	• Width of internal road	As per sanction Plan	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	3	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	2.00 mtr x 1 & 1.50 mtr x 2	2.00 mtr x 2 (1 Iron made & 1 concrete made) & 1.50 mtr x 1	MR
	• Basements	1.50 mtr x 2	2.00 mtr x 1 & 1.50 mtr x 1	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	Halls only	NA
	f. Door Size	2.00 mtr x 3	2.00 mtr x 3	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required for car lift	Provided	MR
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	18	25	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	Two at each Floor	Provided	MR
	• Length of hose reel hose	30mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Alternate Floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	At each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NR	Provided	NR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	Two at each floor	Provided	MR
	• Hose Box	Two at each floor	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	2850 LPM	2850 LPM	MR
	➤ Head of main pump	70 MH	70 MH	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70 MH	70 MH	MR
	➤ Standby Pump out put	2850 LPM	2850 LPM	MR
	➤ Standby Pump Head	40 MH	40 MH	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	2,00,000 Ltr.	2,00,000 Ltr	MR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank	10,000 Ltr.	20,000 Ltr.	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- MCB / ELCB and metal conduit wiring (Concealed wiring), earth leakage circuit breaker have been Provided.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

DO/2019

9/5/19

Ashok Kumar Jaiswal
9/5/19

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

DO/2019

9/5/19

DO/

1. what about mezzanine floor?

2. what about ...

9/5/19

Mezzanine floor is provided