

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / 1068

Dated: 21/5/2019


FIRE SAFETY CERTIFICATE

Certified that the **Angiras Bharti Public School** located at **Lampur Road Banker Narela, Delhi-110040** comprised of **Ground plus 01 upper floors** owned/ occupied by **Angiras Bharti Public School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/2016/School/WZ/378 dated 09/03/2016** The premises was re-inspected by the officer and observed that the school have deemed complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **02.05.2016** in the presence of **Smt. Shakuntala Devi (Principal)** and that the building/premises is fit for occupancy Group B Educational for ground and first floor only with effect from **21.5.19**... for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on **21.5.19**..... at New Delhi


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph:-011-25104544



Copy to : -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Angiras Bharti Public School, Lampur Road Bankner Narela, Delhi-110040.

2/15

INSPECTION REPORT

1. Name & address of the building : Angiras Bharti Public School, Lampur Road Bankner Narela, Delhi-110040.
2. Type of Occupancy : Educational (G+01 Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2016/School/WZ/378 Dated: 09/03/2016
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 02.05.2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Smt. Shakuntala Devi (Principal)
9. Year of Construction : 1995
10. Applicant's letter No. : ABP/174/249 Dated- 07.03.2019

Plot Area- 11816 sq.m Covered Area:762 sq.m class rooms -12 nos students - 280nos

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	4.5	4.5	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors			
	• Basements	1.50m	1.45m & 1.35m	MR(old case)
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	NA	NA	NA	
e. Width of Corridor	NA	NA	NA	
f. Door Size	1 m	1.10m	MR	

