

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2019/NDZ/ 1094

Dated: 22/05/19

FIRE SAFETY CERTIFICATE

Certified that the ASN Sr. Sec. School at Mayur Vihar Phase-1, Delhi, owned/occupied by ASN Sr. Sec. School, comprised of ground plus three upper floors was granted FSC vide letter no- F6/DFS/MS/School/2015/NDZ/1923 Dated 30/10/15. The school building was re-inspected by the officer concerned of this department on 14/05/19 in the presence of Mr. K.L. Luthra (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance circular no. F16/Estate/CC/FS/2011/3298 to 3398 dated 01/03/11 and found that the building (ground plus three) is fit for occupancy Class B "Educational Building" with effect from 22/05/19 for a period of **three** years, subject to conditions printed overleaf.

Issued on 22/05/19 at New Delhi by


(Sunil Chawdhary)

Dy. Chief Fire Officer



To,

The Manager,
ASN Sr. Sec. School,
Mayur Vihar Phase-1, Delhi.

Copy to:-

The Dy. Director of Education
D-Block Anand Vihar, Delhi.

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The porta cabin constructed on terrace of second floor shall not be used for any purpose.

