

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/WZ/2019/ 1069

Dated: 21/05/2019

FIRE SAFETY CERTIFICATE

Certified that the **CNG Dispensing Station**, Located at, **Shakur Pur, Ring Road, New Delhi**, in a building comprised of Ground Floor Only was issued NOC vide Letter No. F-5/(3 A)/DFS/CNG/2007/321 dated- 30/07/2007. The premises was re inspected by the officers concerned of this department on 30/04/2019 in the presence of Mr. GD. Capt. Subir Pabbi and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Hazardous" Group D with effect from 21/5/19 for a period of three years in accordance with **OISD179/** rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/5/19..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. Sh. Alok Sharma, Chief General Manager(Fire & Safety) Indraprastha Gas Limited, IGL Bhawan, Plot No-04,Community Center, R K Puram, Sector-09, new Delhi-110022.
2. CNG Dispensing Station, Located at, Shakur Pur, Ring Road, New Delhi.

Following fire safety directives must be adhered to:-

1. **Only fire protection facilities were checked as per OISD 179 (Para 19). The other safety requirement must be ascertained by licensing authority.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The basement shall be used as per building bye laws 1983.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

