GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.**F6/DFS/MS/EH/2019/NDZ/** 1098 Dated: 22/05/19

FIRE SAFETY CERTIFICATE

Certified that the KFC Eating House at upper ground & Mezzanine floor of building comprised of ground plus three upper floors at Ashok Nagar Metro Station, Delhi, owned/occupied by A Unit of Sapphire Foods India Pvt Ltd have complied with the fire prevention and fire safety requirements in accordance with the rule 35 of the Delhi Fire Service Rules 2010. The restaurant (eating house) was inspected by the officer concerned of this department on 02/05/19 in the presence of Sh. Deepak (Manager) and found that the ground & Mezzanine floor building is fit for occupancy Group D " Restaurant(Eating House) " with effect from .....22/05/19 for a period of three years, subject to conditions printed overleaf.

Issued on .....22/05/19.... at New Delhi by

(Atul Garg)
Chief Fire Officer
Delhi Fire Service

To,

The Deputy Health Officer,
EDMC Health Department, Karkardooma South Zone,
Shahdara, Delhi.

Copy to:-

The Manager,
M/s KFC (A Unit of Sapphire Foods India Pvt Ltd)

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation,ventilation,structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : KFC Eating House (A Unit of Sapphire Foods India Pvt Ltd) at Ashok Nagar Metro Station , Delhi-91.
2. Building is comprised of : ground+3 (**Eating house running at gr. & Mezzanine floor**)
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : New
5. Details of Previous NOC : FS/MS/DFS/2019/660 Dated 29/03/19 (for gr.+3 floors)
6. Fire Safety direction letter No : F6/DFS/MS/BP/2009/3036 Dated 27/10/2009
7. Date of Inspection : 02/05/19
8. Name of the Inspecting Officers: : ADO R.K.Yadav
9. Name of the designation of Officer from the building side : Sh. Deepak (Manager)
10. Year of Construction : 2008
11. Applicant's letter No : Nil Dated 18/03/2019

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement/NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	09 m	12 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits **Common for station**			
	a. Number of Staircases			
	Upper Floor	2 Nos.	2 Nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	2.0 M	2.4,3.2 &1.2 m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	01 no.	02 no.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	2 M	2 M	MR
	i. no. of doors	2 nos.	2 nos.	MR
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Provided	MR

5.	Fire Extinguishers			
	Total numbers for eating house	05 no.	05 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels. Common for metro station			
	Total numbers of each floor	04 Nos	04 Nos	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system. Provided for Metro building			
	Type of detectors	Smoke or heat	smoke	MR
	Location of main panel	Security room	Provided	MR
	Location of repeater panel	N.A.	Provided	MR
	Alternate source of power	Required	Provided	MR
	Hooters	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	Ground floor	Required	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrant	4 no.	4 no.	MR
	Hose Box	4 no.	4no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements. Provided for Metro building			
	• Ground Level			
	➢ Discharge of main Pump	900 LPM	1800 LPM	MR
	➢ Head of Main Pump	40 m	70 m	MR
	➢ Number of main pumps	2 no.	2 no.	MR
	➢ Jockey pump out put	180 LPM	180 LPM	MR
	➢ Jockey pump head	40 m	70 m	MR
	➢ Standby pump out put	900 LPM	1800 LPM	MR
	➢ Standby pump Head	40 m	70 m	MR
	➢ Auto Starting /Manual stopping	Required	Provided	MR
	➢ Pump House Access	Required	Provided	MR
	• Terrace Level	N.A.	N.A.	N.A.
	➢ Discharge of pump	N.A.	N.A.	N.A.
	➢ Head of the Pump	N.A.	N.A.	N.A.
	➢ Power supply	N.A.	N.A.	N.A.
	➢ Auto Starting of pump	N.A.	N.A.	N.A.

N/3

14	Captive Water Storage for Fire Fighting.	Provided for Metro building		
	Underground tank capacity	1,00,000	1,00,000 liters	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Provided for Metro building		
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	N.A.	N.A.	N.A.
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room	Provided for Metro building		
	Detector system panel	Required	Provided	MR
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	Required	Provided	MR
	Batter backup	Required	Provided	MR
	Building Floor Plans	Required	Provided	MR
20	Special Fire Protection systems for protection of special Risks, if any:	Required	Provided at LT & HT Panels	MR

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.The fire safety arrangements for KFC Restaurant (Eating House) is connected to Metro Station building. This department had already issued fire safety certificate for Metro station building vide letter no. F6/DFS/MS/2019/660 Dated 29/03/19.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to grant fire safety certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name : R.K.Yadav
Designation: ADO (LN)

DO (CO)

DY. CFO/ND-4.

Pl. speak