

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/2019/NDZ/ 1093

Dated: - 22/5/19

FIRE SAFETY CERTIFICATE

Certified that the **La Sagrita Guest House** located **14, Sunder Nagari, New Delhi-110003** comprised of Ground + 02 Upper floors, Main Building Ground floor (Reception + 06 Guest Rooms), 1st floor (07 Guest Rooms) 2nd floor (02guest rooms), and Annexe Building 1st floor to 2nd floor (02guest rooms each floor), total 19 guest rooms was granted FSC by this department vide letter **No.F6/DFS/MS/GH/2016/929** dated **03/06/16**. The premises was re-inspected by the officer concerned of this department on **17/05/19** in the presence of **Sh. Hemant Ahuja (Owner)** and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub Division-A-1 as above 19 guest rooms only** with effect from ~~22/5/19~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~22/5/19~~ at New Delhi by


(Sunil Chawdhary)
Dy.Chief Fire Officer
Delhi Fire Service

QC Sec

Copy to:-

1. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi
2. Sh. Hemant Ahuja (Owner),
La Sangrita Guest House located at 14, Sunder Nagari, New Delhi- 110003

Condition for the validity of fire safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior is prohibited.

INSPECTION REPORT

1. Name & address of the building:- La Sangrita Guest House ,14 Sunder Nagari,
New Delhi- 110003.
2. Type of occupancy:- Residential, Sub Division A-1,
Ground + Two upper Floors
(Total 19 Guest Rooms)
3. Type of case:- Renewal
4. Details of previous FSC: - No. F6/DFS/MS/GH/2016/NDZ/929
Dated 03/06/16.
5. Fire safety directives No.- N/A
6. Date of inspection:- 17/05/19
7. Name of the inspecting officer:- Sh. S.K. Dua (DO/CD)
8. Name & designation of officer
From the building side:- Sh. Hemant Ahuja (Owner)
9. Year of construction:- 1982
10. Applicant's letter No:- Nil dated 07/05/19

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site PSS	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Accessible	06 Mtrs. Approx	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 Mtr.	0.85 Mtr & 1.20 Mtrs.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
		N/A	N/A	N/A
	E. Width of corridor			
		N/A	N/A	N/A
	F. Door size			
		01 Mtr.	01 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	Sealed	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	MR
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

- N/27 -

6.	First-Aid Hose Reel			
	1) Total number of each floor	01 Nos.	01 Nos.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	225 LPM	225 LPM	MR
	b) Head of pump	30 Mtrs	30 Mtrs	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 Ltrs.	2500 Ltrs.	MR

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the guest house building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/GH/2016/NDZ/929 dated 03/06/2016 renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

S.K. Dua
18/05

Name: - S.K. Dua
Designation: - DO (CD)

F. T. please

DCFO(NDZ)
[Signature]

[Signature]
20/5

~~DO (CD)~~

FT letter is put up for sig. pl.

S.K. Dua
21/05

DCFO(NDZ)
[Signature]

[Signature]
22/5