

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/Indl./2019/NDZ/ 1097

Dated: 22/05/19

FIRE SAFETY CERTIFICATE

Certified that the Plot no. 82, FIE Patpargang, Industrial area Delhi-92, Comprised of basement, ground plus two upper floors was granted NOC by this department vide letter no. F6/DFS/MS/2016/NDZ/1570 Dated 15/11/16. The premises was re-inspected by the concerned of this department on dated 14/05/19 in the presence of Sh. Paras Jain (Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with BBL & NBC Part-IV and that the building is fit for occupancy Group "G (Industrial Building)", with effect from ...22/05/19... for a period of **three** years, subject to conditions, printed overleaf.

Issued on..... 22/05/19 ..... at New Delhi by

(Atul Garg)  
Chief Fire Officer  
Delhi Fire Service

To,  
The Excutive Engineer (Bldg.)HQ,  
East Delhi Municipal Corporation,  
Udyog Sadan, Patpargang, Industrial Area Delhi-92.

Copy to-

Sh. Paras Jain (Manager),  
Plot no. 82, FIE Patpargang, Industrial area Delhi-92

## INSPECTION REPORT

1. Name & address of the building : Plot no. 82, FIE Patpargang, Industrial area Delhi-92.
2. Building is comprised of : Basement, Ground+2 Upper floors
3. Type of Occupancy : Industrial
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2016/NDZ/1570 Dated 15/11/16
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 14/05/19
8. Name of the Inspecting Officers: : R.K.Yadav (ADO)
9. Name of the designation of Officer from the building side : Sh. Paras Jain (Manager)
10. Year of Construction : 1996
11. Applicant's letter No : dated 11/04/19

S. N	Minimum Standards on fire prevention and fire safety U/R33	BBL/NBC Part-IV	Provided at Site	Remarks MR/NMR	
1	Access to building	12 m	12 m	MR	
	Road width	4.5 m	4.5 m	MR	
	Gate width	N.A.	N.A.	N.A.	
	Width of internal road				
2	Number, Width, Type and Arrangement of Exits				
	a. Number of Staircases	Upper Floor	2 nos.	2 nos.	MR
		Basement	1 no.	1 no.	MR (Old accepted)
	b. Width of Staircases	Upper Floor	1.5 & 1.25 m	1.5 & 1.25 m	MR
		Basement	<del>1.25 m</del> 1.25 m	1.25 m	MR (Old accepted)
	c. Protection of exits	Fire check door	Required	provided	MR
		Pressurization	Required	provided	MR
	e. No. of continuous staircases to terrace	1 no.	1 no.	1 no.	MR
	g. Width of Corridor	1.5 m	1.5 m	1.5 m	MR
	h. Door Size	1.0 m	1.0 m	1.0 m	MR
	3	Compartmentation.			
Fire check door		Required	provided	MR	
Sealing of electrical shafts		Required	Sealed	MR	
Fire rating of shaft door		02 hrs.	02 hrs.	MR	
Water curtain		N.A.	N.A.	N.A.	
Fire Dampers		N.A.	N.A.	N.A.	
4	Smoke Management System.				
	Basement	Required	provided	MR	
Upper floor	N.A.	N.A.	N.A.		
5	Fire Extinguisher				
	Total numbers	40 nos.	40 nos.	MR	
	types	CO <sub>2</sub> & ABC	provided	MR	
IS marking	ISI marked	provided	MR		

