

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6 DFS/MS/School/2019/SZ/ 1071

Dated: 21/05/19

FIRE SAFETY CERTIFICATE

Certified that the St. Paul's Diocesan School located at Hospital Road, Jangpura, New Delhi-110014 comprised of ground plus two upper floors was issued FSC by this department vide letter No F.6/DFS/MS/2015/School/SZ/1898 dated 21/10/2015. The said premises was re-inspected by officer concerned of this department on 08/05/2019 in presence of Mrs. Doris James (Principal) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the school building is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/05/19 at New Delhi by


(Rajesh Panwar)
Dy. Chief Fire Officer
Tel. 011-26189168

Copy to: -

1. The Principal, St. Paul's Diocesan School, Hospital Road, Jangpura, New Delhi-110014
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

