

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001


No.F6/DFS/MS/EH/2019/NDZ/ 11812

Dated: - 23/05/19

FIRE SAFETY CERTIFICATE

Certified that the **M/s Bagundi (A unit of Ramanchil Pvt Ltd)** located at **M-14, Connaught Place, New Delhi- 110001** comprised of Ground + Mezzanine floor, restaurant at ground floor & mezzanine floor only owned/occupied by **M/s Bagundi (A unit of Ramanchil Pvt Ltd)** has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by team of officers concerned of Delhi Fire Service on **16/05/2019** in the presence of Sh. Hari Kumar (Manager) and that the premises is fit for occupancy class **Assembly Building Group D (Restaurant)** with effect from 23/05/19 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 23/05/19 at New Delhi by


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Medical Officer of Health,
Health Department (NDMC), Palika Kendra, New Delhi.
2. Sh. Hari Kumar (Manager),
M/s Bagundi (A unit of Ramanchil Pvt Ltd) located at M-14, Connaught Place, New Delhi- 110001

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. The owner/occupier shall apply for renewal of this fire safety certificate to the director in Form the [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.

INSPECTION REPORT

1. Name & address of the building:- M/s Bagundi (A unit of Ramanchil Pvt Ltd.) at M-14, Connaught Place, New Delhi- 110001.
2. Type of occupancy:- Assembly Group – D Restaurant is running Ground + Mezzanine floor
3. Type of case:- New
4. Details of previous FSC: - N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 16/05/19
7. Name of the inspecting officer:- DCFO Sunil Chawdhary & D.O. S.K. Dua
8. Name & designation of officer
From the building side:- Sh. Hari Kumar (Manager)
9. Year of construction:- Old Heritage
10. Applicant's letter No:- D/259/S.O./(HL)/ JD(HL) dated 01/05/19

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing Fire & Safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	30 Mtrs.	MR
	2) Gate width	1.0 & 2.0 Mtr	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 & 1.0 Mtrs.	1.70 & 1.10 Mtrs.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2.0 & 1.0 Mtrs.	2.0 & 1.0 Mtrs.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

1/2

6.	First-Aid Hose Reel			
	1) Total number of each floor	01 Nos.	01 Nos.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	Provided	N/A
	2) Location of main panel	N/A	Provided	N/A
	3) Location of repeater panel	N/A	Provided	MR
	4) Alternate source of power	N/A	Provided	MR
	5) Hooter's Location	N/A	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 Mtrs	30 Mtrs	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 Ltrs.	20,000 Ltrs.	MR


- 173 -

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the guest house building were randomly tested, checked and found functional at the time of inspection.


Keeping In view the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. Grant of Fire Safety Certificate under rule 35 of the Delhi Fire Service rules 2010 is recommended Please.

Signature of the Inspecting Officer



Name: - Sunil Chawdhary
Designation: - DCFO (NDZ)

Signature of the Inspecting Officer



Name: - S.K. Dua
Designation: - DO (CD)

~~C.F.O. / 29/05/15~~ H 14

F. S. letter is put up for signature please

~~C.F.O. / 29/05~~

