

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6 / DFS / MS/ 2019 / SZ / 1133

Dated: 27/5/19

FIRE SAFETY CERTIFICATE

Certified that the **Police Staff Quarters Building** at Badarpur, New Delhi-110044, comprised of **stilt plus five upper floors** was inspected by officers concerned of this department on 15/05/2019 in presence of Sh. Hira Lal (GM/Engg, NBCC) and found that the said building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Residential Building" with effect from the date of issue of this certificate for a period of **Five Years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/5/19 at New Delhi by


(Anil Garg)
Chief Fire Officer
Tel. 011-23414250

Copy to: -

1. Dy. Commissioner of Police, Land & Bldg Cell, Police Headquarters, I.P. Estate, New Delhi-110 002
2. Sh. Hira Lal, General Manager (Engg.), NBCC (India) Limited, Police Station, Badarpur, New Delhi-110044

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

