

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/2019/ 1122

Dated: 24 / 5 /2019

FIRE SAFETY CERTIFICATE

Certified that the Symphony Celebrators Pvt. Ltd. located at D-11, Udyog Nagar, Delhi-110041, comprised of Basement, Ground + Two Upper Floors only owned / occupied by Symphony Celebrators Pvt. Ltd. with store in Basement, Banquet halls on Ground & 1st Floor & restaurant on 2nd Floor, have already been issued Fire Safety certificate by this department vide letter No. F6/DFS/MS/2016/Banquet/WZ/881 dated 30/05/2016. The premises was re-inspected by the officer concerned of Fire Service on 10/05/2019 in presence of Mr. Jagdish Nagpal (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the Fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Assembly (Banquet Hall)** with effect from 24 / 5 /2019 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24 / 5 /19 at New Delhi by.

(ATUL GARG)

CHIEF FIRE OFFICER.

Copy to :-

1. Mr. Sanjay Gupta (Director), Symphony Celebrations Pvt. Ltd., D-11, Udyog Nagar, Delhi-110041.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six month prior to its expiry".
7. Basement shall be used as per the NBC (Part-IV) read with BBL 1983.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in

INSPECTION REPORT

1. Name & address of the building: Symphony Celebrations Pvt. Ltd., D-11, Udyog Nagar, Delhi-110041.
2. Type of Occupancy : Assembly (Banquet Hall)
3. Type of Case : Renewal (B+G+ 2 Upper Floors only)
4. Details of previous NOC : F6/DFS/MS/2016/Banquet/WZ/881 dated 30/05/2016
5. Fire Safety directives Letter No. : F6/DFS/MS/2000/1728 dated 25/09/2000
F6/DFS/MS/2008/363 dated 13/02/2008
6. Date of inspection : 10/05/2019
7. Name of the Inspecting Officer : A.D.O. (JWP)
8. Name and designation of Officer
from the building side : Mr. Jagdish Nagpal (Manager)
9. Year of Construction : 2002
10. Applicant's letter No. : - Nil

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC / BBL Requirements | Provided at site | Remarks MR/NMR |
|------|---|--|--|----------------|
| 1. | Access of building | | | |
| | • Road width | 06 mtr | 06 mtr | MR |
| | • Gate width | 05 mtr | 05 mtr | MR |
| | • Width of internal road | NR | NR | NR |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 3 | 3 | MR |
| | • Basements | 4 | 6 | MR |
| | b. Width of staircases | | | |
| | • Upper floors | Old Case | 1.82 m, 1.81 m & 1.50 m | MR |
| | • Basements | Old Case | 1.82m, 1.81m, 1.72m, 1.25m, 1.26m & 0.72m | MR |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | MR |
| | • Pressurization | N/A | N/A | N/A |
| | d. No of continuous staircase to terrace | 1 | 1 | MR |
| | e. Width Of Corridor | 1.5 mtr | 1.5 mtr | NR |
| | f. Door Size | Old Case (GF) Old Case (FF) Old Case (2 nd floor) | 2.7m, 2.4m & 1.26m 2.7m, 2.4m & 1.26m 1X2.8 mtrs 1X2.0 mtrs | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | Required | Provided | MR |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire Rating of shaft door | NR | NR | NR |
| | • Water Curtain | NR | NR | NR |
| | • Fire Dampers | NR | NR | NR |
| 4. | Smoke managements System | | | |
| | • Basements | Required | Provided | MR |
| | • Upper floors | Required | Provided | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 28 | 28 | MR |
| | • Types | ISI marked ABC/CO ₂ | Provided | MR |

| | | | | |
|-----|--|-----------------|----------------|-----|
| | • Total numbers on each floor | 2 | 2 | MR |
| | • Length of hose reel hose | 30Mtr. | 30Mtr. | MR |
| | • Nozzle diameter | 5mm. | 5mm. | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | Smoke & Heat | Provided | MR |
| | • Location of Main Panel | On Ground Floor | Provided | MR |
| | • Location of Repeater | NR | NR | NR |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooters' Location | On each floor | Provided | MR |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | Required | Provided | MR |
| | • Upper Floor | Required | Provided | MR |
| | • Sprinkler above false ceiling | NR | NR | NR |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | 100mm | 100mm | MR |
| | • Number of hydrants per floor | 02 | 02 | MR |
| | • Hose Box | 02 | 02 | MR |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NR | NR | NR |
| | • Hose Box | NR | NR | NR |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | 2280 LPM | 2280 LPM | MR |
| | ➤ Head of main pump | 40 MH | 40 MH | MR |
| | ➤ Number of main pumps | 2 | 2 | MR |
| | ➤ Jockey pump out put | 180 LPM | 180 LPM | MR |
| | ➤ Jockey pump head | 40 MH | 40 MH | MR |
| | ➤ Standby Pump out put | 2280 LPM | 2280 LPM | MR |
| | ➤ Standby Pump Head | 40 MH | 40 MH | MR |
| | ➤ Auto Staring/Manual stopping | Auto | Provided | MR |
| | ➤ Pump House Access | Required | Provided | MR |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 900 LPM | 900 LPM | MR |
| | ➤ Head of the pump | 40 MH | 40 MH | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank capacity | 50,000 ltrs. | 1,50,000 ltrs. | M/R |
| | ➤ Draw of connection | Required | Provided | M/R |
| | ➤ Fire service inlet | Required | Provided | M/R |
| | ➤ Access to tank | Required | Provided | M/R |
| | • Overhead Tank capacity | 10,000 ltrs. | 10,000 ltrs | M/R |

N127

| | | | | |
|-----|--|----------|----------|-----|
| 15 | Exit Signage | Required | Provided | M/R |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NR | NR | NR |
| | ➤ Pressurization of lift lobby | NR | NR | NR |
| | ➤ Communication in lift Car | NR | NR | NR |
| | ➤ Fireman's Grounding Switch | NR | NR | NR |
| | ➤ Lift Signage | NR | NR | NR |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area | NR | NR | |
| | ➤ Total area | NR | NR | NR |
| | ➤ Location | NR | NR | NR |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NR | NR | NR |
| | ➤ Flow Switch Panel | NR | NR | NR |
| | ➤ PA System Panel | NR | NR | NR |
| | ➤ Battery backup | NR | NR | NR |
| | ➤ Building Floor Plans | NR | NR | NR |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NR | NR | NR |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2016/Banquet/WZ/881 dated 30/05/2016 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DO / CO D

[Signature]
13/5/19

[Signature]

[Signature]
19/5/19

CFO

[Signature]

[Signature]
21/5/19

F.T. is added for signature please.

[Signature]
13/05/2019

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

[Signature]
21/5/19