

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2019/SZ/ 1138

Dated: 28/5/19

**FIRE SAFETY CERTIFICATE**

Certified that the Delhi Public School, Sector-3, Phase-1, Dwarka, New Delhi-110078, comprised of ground plus three upper floors was issued fire safety certificate by this department vide letter no. F6/DFS/MS/School/2016/SZ/405 dated 14.03.2016. The said premises was re-inspected by the officer concerned of this department on 17.5.2019 in the presence of Sh. R K Nair (Administrator) and found that premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service 2010, and that the school building is fit for occupancy class B "Educational building" (for school building only) with effect from-----28/5/19-----for a period of **three years**, subject to compliance of the conditions printed overleaf.

Issued on .....28/5/19..... at New Delhi by

(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-26189168

Copy to:-

1. The Director, (Education), G.N.C.T. of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Delhi Public School, Sector-3, Phase-1 Dwarka, New Delhi-110078.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

