

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/CGHS/2019/NDZ/ 1134

Dated: 28/5/19

FIRE SAFETY CERTIFICATE

Certified that the IFS Co-operative Group Housing Society Ltd., Plot No.1, Mayur Vihar Phase-1, Delhi-92, comprised of five blocks stilt/parking plus seven upper floors blocks. The building was issued NOC by this department vide Letter no. F.6/DFS/MS/HQ/2005/664 dated-11.11.2005. The residential building was re-inspected by the officer concerned of this department 21/05/19 in the presence of Mrs. Homai Saha (Secretary) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the with the rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class A "Residential" with effect from 28/5/19 for a period of five years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on 28/5/19 at New Delhi by

(Atul Garg)  
Chief Fire Officer  
Delhi Fire Service

To,

1. The Secretary,  
IFS Co-operative Group Housing Society Ltd.,  
Plot No.1, Mayur Vihar Phase-1, Delhi-92.

Copy to:-

1. Registrar of Cooperative Societies, GNCT of Delhi,  
Sansad Marg, New Delhi-110001.

## CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, six months prior to its expiry.

