**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO.F6/DFS/MS/School/2019/SZ/ 1137 Dated: 28/5/19

**FIRE SAFETY CERTIFICATE**

Certified that the Vandana Kindergarten, located at Sector-10 phase-1, Dwarka, New Delhi-110075, comprised of ground plus two upper floors was issued fire safety certificate by this department vide letter no.F6/DFS/MS/School/2016/SZ/1516 dated 17.10.2016. The premises was re-inspected by the officer concerned of this department on 18.4.2019 in presence of Sh. V K Tobdon (Director) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 under DFS Act 2007 and that the building is fit for occupancy class B "Educational building" with effect from....28/5/19.... for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on .....28/5/19..... at New Delhi by

(Rajesh Panwar)
Dy.Chief Fire Officer

Copy to:-

1. The Dy. Director, (Education), G.N.C.T of Delhi, Old Secretariat, New Delhi-54
2. The Principle, Vandana KinderGarten, Sector-10, Phase-1, Dwarka, New Delhi-110075.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.