

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/BNQT/2019/NDZ/ 1148

Dated: 29/05/19

**FIRE SAFETY CERTIFICATE**

Certified that the Vatika Palace Banquet Hall running at ground & first floor of the building at 512/2-B, Jheel Kuranja, Geeta Colony Chowk, Delhi-51, comprised of basement, ground plus two upper floors owned/occupied by M/s Vatika Palace Banquet Hall was granted FSC by this department vide letter no. F6/DFS/MS/BNQT/2016/677 Dated 29/04/16. The Banquet Hall was re-inspected by the officer concerned of this department on 18/04/19 in the presence of Sh. Sunil Kumar Kathuria (Owner) and found that the Assembly building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 35 of the Delhi Fire Service Rule 2010, and that the Banquet Hall (GF+FF) is fit for occupancy "Assembly building (Banquet Hall)" with effect from 29/05/19 for a period of three years, subject to conditions printed overleaf.

Issued on 29/05/19 at New Delhi by

(Atul Garg)  
Chief Fire Officer

9/1/19

To,

1. The Manager,  
Vatika Palace Banquet at 512/2-B,  
Jheel Kuranja, Geeta Colony Chowk, Delhi-51.
2. The Dy. Health Officer,  
East MCD Health Department,  
Shahdara South Zone, Karkardooma, Shahdara Delhi.

### CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, six months prior to its expiry.

