

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/FH/2019/SZ/ 1149

Dated: 30/5/19

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Bird Travels Motel Building** located at Khasra No. 18/4/2/2, 18/11, 1/8/12 & 18/13, Village Samalkha, New Delhi-110037, comprised of basement (storage & services), ground floor (reception + 20 guest rooms) and 1<sup>st</sup> floor (11 guest rooms), total 31 guest rooms, owned/occupied by M/s Bird Travels Pvt. Ltd was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/FH/2016/SZ/456 dated 23/03/2016. The premise was re-inspected by officer concerned of this department on 17/05/2019 in the presence of Sh. V.K. Malhotra (Liaison Officer) and found that the said motel building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" (Motel with 31 guest rooms only) with effect from 30/5/2019 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Rules 2010.

Issued on 30/5/19 at New Delhi by

  
(Atul Garg)

Chief Fire Officer  
Ph: 011-23414250

Copy to: -

1. The Joint Commissioner of Police (Lic.), Ist Floor, P.S. Defence Colony, New Delhi-110049
2. M/s Bird Travels Motel Building, Khasra No. 18/4/2/2, 18/11, 1/8/12 & 18/13, Village Samalkha, New Delhi-110037

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the First schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not be treated as regularization (Clause 2.8 of UBBL- 2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

