GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001
Fax No:- 01123412593, Ph. No. 011-23414250

NO. F6/DFS/MS/ Indl./2019/WZ/ 1147 DATED: 29/5/19

FIRE SAFETY CERTIFICATE

Certified that the Industrial Building, Plot No. 8A, Industrial Area, Shivaji Marg Najafgarh Road, New Delhi- 110015 comprised of Two Basement, Ground, Stilt plus Seven Upper Floors owned/occupied by M/s Divisha Projects LLP (Divisha Projects Pvt. Ltd.) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 24.05.2019 in the presence of Sh. Raghwendra Kumar of the building and that the building is fit for occupancy class G-1 " Industrial Building" with effect from.....29/05/19.....for a period of 3 (**three**) years, accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010,subject to condition as mentioned below.

Issued on.....29/05/19. at New Delhi by

29/05/19

Atul Garg
Chief Fire Officer

Copy To:-

1. The Executive Engineer (B) HQ., NDMC, MCD. 8th Floor, Civic Centre, Minto Road, New Delhi-110002,
2. The Designated Partner, M/s Divisha Projects LLP (Converted from Divisha Projects Pvt. Ltd.), 10/60, Industrial Area, Kirti Nagar, New Delhi-110015.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.