

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2019/SZ/ 1160

Dated: 31/5/19

**FIRE SAFETY CERTIFICATE**

Certified that **The British School including Auditorium** located at Dr. Jose P Rizal Marg, Chanakyapuri, New Delhi-110021, comprised of 02 tier basements, ground plus four upper floors was issued FSC by this department vide letter No. F6/DFS/MS/School/2016/SZ/1326 dated 31/08/2016 (School) & F6/DFS/MS/School/2016/SZ/1494 dated 10/10/2016 (Auditorium). The premise was re-inspected by officer concerned by this department on 22/05/2019 in the presence of Mr. Yashpal (Manager-Estate) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Group-B, Education Building**" (School upto Sr. Secondary level including Auditorium ) with effect from 31/5/19 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued 31/5/19 at New Delhi by

  
(Atul Garg)  
Chief Fire Officer  
Tel: 011-23414250

Copy to: -

1. Gp. Capt. Sanjay Kumar Singh, The British School at Dr. Jose P Rizal Marg, Chanakyapuri, New Delhi-110 021
2. The Executive Engineer (Bldg.), New Delhi Municipal Council, Palika Kendra, New Delhi-01

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry?"

