

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2019/SZ/ 1192

Dated: 4/6/19

FIRE SAFETY CERTIFICATE

Certified that the **Daisy Dales International School**, Vikas Puri, New Delhi-110018, comprised of basement, ground floor plus three upper floors, owned/occupied by Daisy Dales International School was issued FSC by this department vide letter no. F.6/DFS/MS/School/2016/SZ/447 dated 21.03.2016. The School building was re-inspected by the officer concerned of this department on 22.05.2019 in the presence of Smt. Garima (Accounts) and found that Daisy Dales International School have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.


Issued on.....4/6/19..... at New Delhi.



(RAJESH PANWAR)  
Dy. CHIEF FIRE OFFICER  
SOUTH ZONE

Copy to:-

1. The Principal,  
Daisy Dales International School,  
Vikas Puri, New Delhi-110018.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : Daisy Dales International School, Vikas Puri, New Delhi-110018
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2016/SZ/447 dated 21.03.2016
5. Fire Safety directives letter No : N/A
6. Date of inspection : 22.05.2019
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers  
From the building side : Smt. Garima (Accounts)
9. Year of Construction : 1996 (G+II) & 2015 (B+G+III)
10. Applicant's letter No. : Nil dated 27.03.2019.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Dir. of Edu. Cir. Dt. 01.03.2011 requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible (06 mtrs.) 4.5 mtrs NA	Provided Directly accessible from road NA	MR MR NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basement</li> </ul>	02 No's 02 No's	02 No's 02 No's	M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	150 cms 150 cms	150 & 150 cms 150 & 150 cms	M/R M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	Required N/A	Provided N/A	MR N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
	f. Class room Door Size			
		Required 150 cms	Provided 165 cms	MR M/R
		100 cms	100 cms (double doors)	M/R
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	Required	Exhaust fans Provided	MR
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Natural ventilation & Exhaust fans	M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	14 no's ABC/CO <sub>2</sub> type ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	One 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R



7.	Automatic fire detection and alarming system		N/A	N/A	N/A
	<ul style="list-style-type: none"><li>Type of detectors</li><li>Location of Main Panel</li><li>Location of Repeater Panel</li><li>Alternate source of power</li><li>Hooters' Location</li></ul>	N/A	N/A	N/A	
8.	MOEFA	N/A	N/A	N/A	
9.	Public Address System				
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"><li>Basement</li><li>Upper floors</li><li>Sprinkler above false ceiling</li></ul>	Required	Provided	M/R	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
11.	Internal Hydrants				
	<ul style="list-style-type: none"><li>Size of riser/down-comer</li><li>Number of hydrants per floor</li><li>Hose Box</li></ul>	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
12.	Yard Hydrants				
	<ul style="list-style-type: none"><li>Total number of hydrants</li><li>Hose Box</li></ul>	N/A	N/A	N/A	
		N/A	N/A	N/A	
13.	Pumping Arrangements				
	<ul style="list-style-type: none"><li>Ground Level<ul style="list-style-type: none"><li>Discharge of main Pump</li><li>Head of Main pump</li><li>Number of main pumps</li><li>Jockey Pump out put</li><li>Jockey pump head</li><li>Standby Pump out put</li><li>Standby Pump Head</li><li>Auto Starting/Manual Stopping</li></ul></li></ul>	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
	<ul style="list-style-type: none"><li>Pump House Access</li><li>Terrace level<ul style="list-style-type: none"><li>Discharge of pump</li><li>Head of the pump</li><li>Power Supply</li><li>Auto Starting of pump</li></ul></li></ul>	900 LPM	Provided	M/R	
		30 mtrs	Provided	M/R	
		Required	Provided	M/R	
		Required	Provided	M/R	
14.	Captive Water Storage for fire fighting				
	<ul style="list-style-type: none"><li>Underground tank capacity<ul style="list-style-type: none"><li>Draw-off connection</li><li>Fire service inlet</li><li>Access to tank</li></ul></li><li>Overhead Tank capacity</li></ul>	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		15000 ltrs	Provided	M/R	
		Required	Provided	M/R	
15.	Exit Signage.			(No Lift)	
16.	Provision of Lifts.				
	<ul style="list-style-type: none"><li>Pressurization of Lift Shaft</li><li>Pressurization of Lift lobby</li><li>Communication In lift Car</li><li>Fireman's Grounding Switch</li><li>Lift Signage</li></ul>	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	Provided	N/A	
17.	Standby power supply				
18.	Refuge Area.				
	<ul style="list-style-type: none"><li>Total Area</li><li>Location</li></ul>	N/A	N/A	N/A	
		N/A	N/A	N/A	


2/15

Comprised of basement, ground plus three upper floors


19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2016/SZ/447 dated 21.03.2016 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


  
Signature of Inspecting Officer  
Name:- Sandeep Duggal  
Designation:- Asstt. Divisional Officer

D.O. (South West)

  
28/5/18

DCFO (S2)


  
28/5




ADD (GK) - E/L

A-T. letter is put up for Sign please.

DCFO (S2)



  
3/6

