

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/EH/2019/NDZ/ 1189

Dated: 4/6/19

FIRE SAFETY CERTIFICATE

Certified that the M/s Pind Balluchi Restaurant running at basement, ground plus two upper floor of the building comprised of basement, ground plus four upper floor at 410, Karkardooma Village, Delhi110096, owned/occupied by a unit of M/s Royal Cuisine was issued FSC vide letter No. F6/DFS/MS/EH/2016/829 dated 20/05/16. The premises was re-inspected by the officer concerned of this department in the presence of Mr. Ashu Sharma, Owner and found that the restaurant have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that restaurant building is fit for occupancy Group D "Assembly Building" with effect from 4/6/19 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 4/6/19 at New Delhi by

  
(Atul Garg)  
Chief Fire Officer

To,

M/s Pind Balluchi Restaurant  
(A Unit of M/s Royal Cuisine)  
410, Karkardooma Village,  
Delhi110096

Copy To:-

The Joint Commissioner of Police (Lic.)  
First floor, Police Station Defence Colony  
New Delhi

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

