

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/GH/SZ/2019/

1207

Dated: 6/6/19

FIRE SAFETY CERTIFICATE

Certified that M/s **The Athena Guest House** located at 19, Eastern Avenue, Maharani Bagh, New Delhi, comprised of Basement, Ground plus three upper floors was issued FSC by this department vide letter No. F6/DFS/MS/GH/2016/SZ/1002 dated 10/06/2016. The said premises was re-inspected by officer concerned of this department on 30/05/2019 in the presence of Sh. Prem Bist (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that premises is fit for (Ground floor: 04 guest rooms, 1st floor: 08 guest rooms, 2nd floor: 08 guest rooms & 3rd floor: 08 guest rooms, total 28 guest rooms) occupancy class "**Residential, Group-A**" (Lodging & Rooming House only) with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued 6/6/19 at New Delhi by

(Rajesh Panwar)
Dy. Chief Fire Officer
Ph: 011-26189168

Copy to: -

1. The Joint Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049
2. Proprietor, M/s The Athena Guest House located at 19, Eastern Avenue, Maharani Bagh, New Delhi-110014

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

