

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2019 / 1252

Dated 11/6/19

**FIRE SAFETY CERTIFICATE**

Certified that the **Bathla Motels (MH-1) Village Bakoli, Main G T\_Karnal Road, Delhi-110036** comprised of **Basement & ground & one upper floor only** owned/ occupied by **Bathla Motels** was issued fire safety certificate vide letter no. **F6./DFS/MS/Motel/2018/1407** dated **15/06/2018** for basement & Ground floor & one upper floor only. The premise was re-inspected by the officer concerned of this department on **28.05.2019** in the presence of **Sh. M.P.Khurana** and observed that the party has added one party hall on ground floor & basement for storage in the existing basement and ground & one upper floor building. All the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under "**Assembly**" with effect from ...11.../6.../19... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The use of basement shall be in accordance with the provision contained in UBBL 2016/ NBC Part 4, 2016.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
9. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on ...11.../6.../19... at New Delhi by

(Atul Garg)

Chief Fire Officer  
Ph-011-23414250

Copy to:-

1. The Director, New Party Hall located at Bathla Motels (MH-1) Village Bakoli, Main G T\_Karnal Road, Delhi-110036.
2. The Excutive Engineer Building, Headquarters, Building Department, North Delhi Municipal Corporation of Delhi for information.

