

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2019/SZ/ Pete/1209

Dated: 6/6/19

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Bedi Motors**, Retail Outlet (Petrol, Diesel & CNG Pump) located at Kemal Attaturk Marg, Near Race Course, New Delhi-110003, comprised of ground floor only was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/2016/775 dated 16/05/2016. The premise was re-inspected by the officer concerned of this department on 28/05/2019 in the presence of Mr. Manish Dagar (Partner) and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Hazardous, Group-J**" with effect from 6/6/2019 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 6/6/19 at New Delhi by

  
(Atul Garg)  
Chief Fire Officer  
Tel. 011-23414250

Copy to: -

1. M/s Bedi Motors, Retail Outlet (Petrol, Diesel & CNG Pump) situated at Kemal Attaturk Marg, Near Race Course, New Delhi-110003

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

