

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/GH/2019/SZ/ 1205

Dated: 06/06/19

FIRE SAFETY CERTIFICATE

Certified that M/s **Hotel Ramhan** located at A-125, NH-8, Mahipalpur Extension, New Delhi-110037, comprised of basement, ground plus three upper floors was issued FSC for 34 guest rooms only by this department vide letter No. F.6/DFS/MS/GH/2018/SZ/613 dated 06/04/2018. The premises was re-inspected by officer concerned of this department on 06/04/2019 in the presence of Mr. Manoj Kumar (Manager) to verify the compliance of minimum standard on fire prevention and fire safety measures for the addition of 46 guest rooms at 2nd & 3rd floor and found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, and that the premises is fit for (**Ground Floor: Rec., 10 rooms & conference hall, 1st Floor: 24 rooms, 2nd Floor: 24 rooms & 3rd Floor: 22 rooms & meeting room, total 80 guest rooms**) occupancy class "Residential, Group-A" (Guest House only) with effect from the date of issue of this certificate for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued 06/06/19 at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph: 011-23414250
OK

Copy to: -

1. Dy. Health Officer, South MCD, Public Health Department, Najafgarh Zone, Dhansa Stand, Najafgarh, New Delhi-110043
2. Proprietor, M/s **Hotel Ramhan** at A-125, NH-8, Mahipalpur Extension, New Delhi-110037

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."
7. The FSC is for Guest House only.

