

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / GH / 2019 / 1260

Dated: 12/ 6 / 2019


FIRE SAFETY CERTIFICATE

Certified that the **M/s Royal Palace Guest House, A-55, Sarai Pipal Thala Extn, Adarsh Nagar, Delhi-110033** located at first floor having 08 guest rooms in the building comprised of basement, ground and 02 upper floors owned/ occupied by **M/s Royal Palace Guest House** was issued fire safety certificate vide letter no. **F6/DFS/MS/2016/GH/WZ/771 dated 13/05/2016**. The premises was re-inspected by the officer concerned of Fire Service on 02/05/2019 in the presence of **Sh. P.C. Verma** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety accordance with rule 33 of the Delhi Fire Service rule 2010 for a period, of **three years** in accordance with rules 36 unless renewed under rule. 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. If any temporary structure is constructed on terrace, than this Fire Safety Certificate should be treated as nul & Void.
10. This Fire Safety Certificate is valid for Guest House only.

Issued on 12/16/19 at New Delhi by


(Dharmpal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25104544

Copy to :-

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station, Defence Colony, New Delhi.
2. The Manager, M/s Royal Palace Guest House, A-55, Sarai Pipal Thala Extn, Adarsh Nagar, Delhi-110033

