

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F.6/DFS/MS/GH/SZ/2019/1240

Dated: 11/06/2019

FIRE SAFETY CERTIFICATE

Certified that M/s **Satwah-29** Guest House located at 29, Church Road, Bhogal, New Delhi, comprised of Ground plus three upper floors was issued FSC by this department vide letter No. F6/DFS/MS/GH/SZ/2016/702 dated 05/05/2016. The premises was re-inspected by officer concerned of this department on 31/05/2019 in the presence of Mr. Sonu (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that premises is fit for (Ground floor: 03 rooms, 1st floor: 03 rooms, 2nd floor: 06 rooms & 3rd floor: 06 rooms, total 18 guest rooms) occupancy class "**Residential, Group-A**" (Lodging & Rooming House only) with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued 11/06/2019 at New Delhi by


(Rajesh Panwar)
Dy. Chief Fire Officer
Ph: 011-26189168

Copy to: -

1. The Joint Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049
2. Proprietor, M/s Satwah-29 Guest House at 29, Church Road, Bhogal, New Delhi-110014

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

