

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Audi/2019/SZ/1237

Dated: 11/06/2019

**FIRE SAFETY CERTIFICATE**

Certified that M/s Weightlifting Auditorium, Jawahar Lal Nehru Sports Complex located at Lodhi Road, New Delhi-110003, comprised of two basements, ground plus one upper floor was issued FSC by this department vide letter No. F6/DFS/MS/SZ/2016/2056 dated 16/11/2015. The said premise was re-inspected by the officer concerned of this department on 08/04/2016 in presence of Sh. R.N. Singh (Ex. Engineer) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy class **Assembly Building Group-D** (Auditorium) with effect from 11/06/2019 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 11/06/19 at New Delhi by

(Atul Garg)  
Chief Fire Officer  
Ph: 011-23414250

Copy to:

1. The Administrator, JLN Stadium Complex, Lodhi Road, New Delhi-110003
2. Asstt. Engineer (E), Safdarjung Hospital Sub-Division-V, C.P.W.D, New Delhi-110029

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of DFS Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

