

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2019 / 1256

Dated: 12 / 6 / 2019

**FIRE SAFETY CERTIFICATE**

Certified that the **Mata Sunder Kaur Public School** located at **1631, Sohan Ganj, Near Kolhapur Raod, Delhi-110007** comprised of **Ground floor Only** owned/ occupied by **Mata Sunder Kaur Public School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/2016/School/WZ/221 dated 05.02.2016**. The premises was re-inspected by the officer and observed that the school have deemed complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **23.05.2019** in the presence of **Sh. Inderpreet Singh (Chairmen)** and that the building/premises is fit for occupancy Group B Educational for ground and first floor only with effect from **12/6/19**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. The number of students in the class rooms shall not be more than 45 as there are single exit door in class room.

Issued on **12/6/19**..... at New Delhi

  
(Dharampal Bhardwaj)  
Dy.Chief Fire Officer  
Ph:-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Manager, Mata Sunder Kaur Public School, 1631/32, Sohan Ganj, Delhi-110007.

