

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2019 / 1255

Dated: 12/6/2019


**FIRE SAFETY CERTIFICATE**

Certified that **Oscar Public School** located at **Kaushik Enclave, Swaroop Nagar Road, Delhi-110086** comprised of **03 blocks – 02 blocks - Ground & one upper floor and 01 block- Ground floor only** was granted FSC by this department vide letter no. **No.F6/DFS/MS/SCHOOL/2015/WZ/691 dated 07.05.2015**. The premises was re-inspected by the officer concerned of this department on 23.05.2019 in presence of **Sh. Lalit Gupta, Manager** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from ...12/6/19.... for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on ...12/6/19..... at New Delhi

  
(Dharmpal Bhardwaj)  
Dy.Chief Fire Officer  
Ph:-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54
2. The Principal, Oscar Public School, Kaushik Enclave, Swaroop Nagar, Delhi-110086.

