

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001



No. F.6 DFS/MS/School/2019/SZ/ 1291

Dated: 17.6.19

FIRE SAFETY CERTIFICATE

Certified that the Sai Shankar Vidhya Niketan (Play way) located at Block-E2, 3343/8, Molarband Extension, Badarpur, New Delhi-110044, comprised of basement, ground plus first floor (basement-storage, ground and first floor used for school) was inspected by the officer concerned of this department on 27/05/2019 in the presence of Mr. Chander Bhan (Manager) of the school and observed that school building have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "Educational Building" Group-B with effect from the date of issue of this certificate for a period of **Three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/6/19 at New Delhi by


(Atul Garg)
Chief Fire Officer
Tel.011-23414250


Copy to: -

1. The Manager, Sai Shankar Vidhya Niketan (Play way) at Block-E2, 3343/8, Molarband Extension, Badarpur, New Delhi-110044
2. The Dy. Director of Education (South), Directorate of Education (Distt. South), Sect-3, R.K. Puram, New Delhi.-110022

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

