

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/Mercantile/SZ/2019/ 1302

Dated: 18/6/19

FIRE SAFETY CERTIFICATE

Certified that the **Southern Park** situated at Plot No. D-2, Saket District Centre, Saket, New Delhi is comprised of 2 tiers Basement, Ground & Five Upper Floors has already been issued FSC vide letter no. F6/MS/DFS/SZ/Mercantile/2015/1415 dated 04/08/2015. The premise was re-inspected by the officer concerned of this department on 12/06/2019 in the presence of Sh. Dalbeer Singh (Building Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the premise is fit for occupancy **Class-F "Mercantile"** with effect from 18/6/2019 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....18/6/19.....at New Delhi by.

(Atul Garg)
Chief Fire Officer
Tel: 011-23414250

Copy to:-

1. The Executive Engineer (Bldg.), SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024.
2. Sh. Dalbeer Singh (Building Manager), Southern Park, Plot No. D-2, Saket District Centre, Saket, New Delhi.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

