

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2019/ 1233

Dated: 10/06/19

FIRE SAFETY CERTIFICATE


Certified that **Govt. Boys Sr. Sec. School located at Dev Nagar, New Delhi- 110005** is comprised of ground plus two upper floors was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2015/SZ/1698 dated 16/09/2015. The school building was re-inspected by the officer concerned of this department on 24/05/2019 in presence of Sh. S.P. Dalal, head of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the under mentioned conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on 10/06/19 at New Delhi by.


Dy. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

Copy to: -

1. The H.O.S, Govt. Boys Sr. Sec. School located at Dev Nagar, New Delhi- 110005.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054.

9c 

1. Name & address of the building : Govt. Boys Sr. Sec. School, Dev Nagar, New Delhi- 05.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2015/SZ/1698 dated 16.09.2015
5. Fire Safety directives letter No : N/A
6. Date of inspection : 24.05.2019
7. Name of the Inspecting Officers : M.K. Chattopadhyay, Divisional Officer (South West)
8. Name and designation of officers from the building side : Sh. S.P. Dalal
9. Year of Construction : Before 1996
10. Applicant's letter No. : GBSSS/DN/2018-19/783 dated 04.04.2019

The said school building is comprised of ground plus two upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire Safety Requirements as per circular of DoE dt. 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width 	06 mts	Provided	MR
	<ul style="list-style-type: none"> • Gate width 	4.5 mts	Directly accessible from the road	MR
	<ul style="list-style-type: none"> • Width of internal road 	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors 	02 Nos.	Provided	MR
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors 	1.5 mts or less & 0.75 mt.	1.70 & 160 mts.	MR
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization 	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	02	02	MR
	h. Door Size	N/A	N/A	N/A
		1.0 mt.	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Natural ventilation provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ type	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR

