

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Industrial/2019/WZ/ 1303

Dated: 18/6 /2019

FIRE SAFETY CERTIFICATE

Certified that the M/s Starlite Rubbers Pvt. Ltd. located at H-39, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041 comprised of Basement, Ground Floor, Mezzanine Floor and First Floor only owned / occupied by M/s Starlite Rubbers Pvt. Ltd., has already been issued Fire Safety Certificate vide letter No. F6/DFS/MS/industrial/2012/517 dated 16.02.2012. The premises / Building was re-inspected by the officer concerned of Fire Service on 22.05.2019 in the presence of Sh. Vikash Dhir (Manager) and found that building / premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Industrial Group (G)** with effect from 18/6 /2019 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 18/6/19 at New Delhi by.

(ATUL GARG)

CHIEF FIRE OFFICER.

Copy to :-

1. Sh. Sumit Bhatia (Director), M/s Starlite Rubbers Pvt. Ltd., H-39, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **M/s Starlite Rubbers Pvt. Ltd.**, H-39, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041.
2. Type of Occupancy : Industrial (Class-G)
3. Type of Case : Renewal (Basement + G.F. +Mezz.F.+1st Floor)
4. Details of previous NOC : No.F6/DFS/MS/industrial/2012/517 dated 16.02.2012
5. Fire Safety directives Letter No. : F6/MS/DFS/84/BP/767 dated 26.09.1984
6. Date of inspection : 22/05/2019
7. Name of the Inspecting Officer : A. K.-Jaiswal
8. Name and designation of Officer
from the building side : Sh. Vikash Dhir (Manager)
9. Year of Construction : 1992-93

10. Applicant's letter No. : -Nil Diary No. 12 Mar.2019

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	12 mtr.	MR
	• Gate width	4.5 mtr	5 mtr	MR
	• Width of internal road	3 mtr	3 mtr	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	3	MR
	b. Width of staircases			
	• Upper floors	1.20	1.20 mtr x 2	MR
	• Basements	1.20	2.00 x 1, 1.80 x 1, 1.40 x 1	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	2	2	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.50 mtr	1.50 mtr	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	Provided	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	Required	Exhaust Fan Provided	MR
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	14	20	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR



6.	• First – Aid Hose Reels			
	• Total numbers on each floor	2	2	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater	N/A	N/A	N/A
	• Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	2	2	MR
	• Hose Box	2	2	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 Lit/min.	450 Lit/min.	MR
	➤ Head of the pump	40 mtr.	40 mtr.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	50,000 lts.	50,000 lts.	M/R
	➤ Draw of connection	Required	Provided	M/R
	➤ Fire service inlet	Required	Provided	M/R

N/17

15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/industrial/2012/517 dated 16.02.2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DO/COO

[Signature] 27/5/19

[Signature]
23/5/19

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

[Signature]

[Signature] 29/5/19

[Signature] 30/5/19

How basement has come now?

[Signature]
20/5/11

[Signature] 30/5/19

Basement already existed.