

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/School/2019/NDZ/ 1334

Dated: 24/6/19

FIRE SAFETY CERTIFICATE

Certified that the M/s Govt. Girls Sr. Sec. School at Kailash Nagar, Delhi-110031, comprised of ground plus three upper floors owned/occupied by Govt. Girls Sr. Sec. School was issued FSC vide letter No. F6/DFS/MS/School/2015/1454 dated 12/08/15. The school buildings were re-inspected by the officer concerned of this department in the presence of Mr. Sanjay Singh, Estate Manager of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school buildings is fit for occupancy class "B" 'Educational Building' with effect from 24/6/19 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 24/6/19 at New Delhi by



(Sunil Chawdhary)
Dy.Chief Fire Officer

To,
The Principal,
M/s Govt. Girls Sr. Sec. School
Kailash Nagar,
Delhi-110031

Copy:-
The Dy. Director of Education,
B- Block, Yamuna Vihar,
Delhi-110053

oe
ok

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

