

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2019/NDZ/ 1333

Dated: 24/6/19

FIRE SAFETY CERTIFICATE

Certified that the M/s Sarvodaya Kanya Vidyalaya at Shankar Nagar (Gandhi Nagar), Delhi-110031, comprised of ground plus first floor, owned/occupied by M/s Sarvodaya Kanya Vidyalaya was issued FSC vide letter No. F.6/DFS/MS/School/2016/NDZ/789 dated 17/05/16. The school building was re-inspected by the officer concerned of this department in the presence of Mr. Neeraj Kaushik, Estate Manager of the school and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No.F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from ..24.6.19.. for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....24/6/19.....at New Delhi by



(Sunil Chawdhary)
Dy.Chief Fire Officer

To,
The Principal
M/s Sarvodaya Kanya Vidyalaya
Shankar Nagar (Gandhi Nagar),
Delhi-110031

Copy:-
The Dy. Director of Education,
B- Block, Yamuna Vihar
Delhi-110053

oe
ok

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

