

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F.6/DFS/MS/School/2019/SZ/ 1372

Dated: .....24/06/19

**FIRE SAFETY CERTIFICATE**

Certified that the **Shalimar Public School** located at A-139, Mahipalpur, New Delhi-110037, comprised of ground plus two upper floors, owned/occupied by Shalimar Public School was issued FSC by this department vide letter No. F6/DFS/MS/School/2014/SZ/1603 dated 19/12/2014. The premise was re-inspected by officer concern of this department on 14/06/2019 in presence of Mr. Dharmendra (Owner) and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Educational**" Group-B with effect from 24/6/2019 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on ..24/6/19... at New Delhi by

  
(Rajesh Panwar)  
Dy. Chief Fire Officer  
Tel. 011-26189168

Copy to: -

1. Manager, Shalimar Public School located at A-139, Mahipalpur, New Delhi-110037
2. Dy. Director of Education (South), Directorate of Education (South District), Govt. of NCT of Delhi, Sector-3, RK Puram, New Delhi-110022

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

