

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO.F6/DFS/MS/School/2019/SZ/ 1336

Dated: 26/6/19

**FIRE SAFETY CERTIFICATE**

Certified that the Kamal Model Sr.Sec.School K-1 Extn.Mohan Garden,New Delhi-110059, comprised of basement, ground plus three upper floors owned/occupied Kamal Model Sr. Sec. School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2016/SZ/1609 dated 31.10.2016.The said school building was re-inspected by the officer concerned of this department on 18.06.2019 in presence of Sh.V.P.Tandon (Chairman) and found that the premises have deemed complied rule 33 of the Delhi fire Service Act 2007 & Rules 2010 and that the premises/building is fit for occupancy class B "Educational building" with effect from...26/6/19.. for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on .....26/6/19... at New Delhi by

(Rajesh Panwar)  
Dy. Chief Fire Officer  
Ph. 011-26189168  
JPC  
Sey

Copy to:-

1. The Dy.Director (Education), G.N.C.T of Delhi, Old Secretariat, New Delhi-110054.
2. Sh.V.P.Tandon (Chairman), Kamal Model Sr.Sec.School at K-1 Extn.Mohan Garden, New Delhi-110059.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

