GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. **F6/DFS/MS/WZ/2019/** 1366 Dated: 2/7/19

FIRE SAFETY CERTIFICATE

Certified that the Ecstasy Hotels Pvt. Ltd. (Banquet Hall) located at 78, 78/1, 81/1, 81/2 block 2, (formerly it was 2/78) W.H.S. Kirti Nagar, New Delhi-15 in a building comprised of Ground Floor (Banquet Hall), 1st Floor (Restaurant) & 3 Office Rooms on terrace only was granted NOC / FSC by the department vide letter No. F6/DFS/MS/Banquet/2016/WZ/936 dated 03/06/2016. The premises was Re-inspected by the officer concerned of this department on 06/06/2019 in presence of Mr. Manoj Kumar (Electrician) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Assembly" (Group-D) with effect from ..2/7/19.....for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 2/7/19 **at New Delhi by.**

(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to :-

1. Sh. Sandeep Kumar (Director), Ecstasy Hotels Pvt. Ltd. (Banquet Hall), 2/78 to 78, 78/1, 81/1, 81/2 block 2, (formerly it was 2/78) W.H.S. Kirti Nagar, New Delhi-15.
2. Dy. Health Offier, North Delhi Municipal Corporation, Nigam Bhawan, DB Gupta Road, Anad Parabt, Karol Bagh, New Delhi-110005.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The from is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Ecstasy Hotels Pvt. Ltd. (Banquet Hall), 78, 78/1, 81/1, 81/2 block 2, (formerly it was 2/78) W.H.S. Kirti Nagar, New Delhi-15.
2. Type of Occupancy : Assembly (Ground Floor-Banquet Hall, 1st Floor-Restaurant & 3 Office Rooms on terrace)
3. Type of Case :Renewal
4. Fire Safety directives Letter No. : F6/DFS/MS/Banquet/2016/WZ/936 dated 03/06/2016
5. Date of inspection : 06/06/2019
6. Name of the Inspecting Officer : A. K.-Jaiswal A.D.O. (Jwp.)
7. Name and designation of Officer from the building side : Mr. Manoj Kumar (Electrician)
8. Year of Construction : 1999
9. Applicant's letter No. : -Nil DATED 24/05/19

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	12 mtr	MR
	• Gate width	4.5 mtr	On main road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50mtr & 1.00mtr	1.52mtr & 1.05mtr	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 mtr & 1 mtr	GF-2.23mtr x2 1.50mtr x2, 1mtr , FF-2.00mtr & 1.50 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	6	8	M/R
	• Types	ISI marked ABC/CO_2	Provided	M/R
	• IS marking	Required	Provided	M/R.

6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	2	MR
	• Length of hose reel hose	30mtr.	30mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	Smoke	NA
	• Location of Main Panel	NA	GF	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	Provided	NA
	• Hooters' Location	NA	GF	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	2	2	MR
	• Hose Box	2	2	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	NR	NR	NR
	➢ Head of main pump	NR	NR	NR
	➢ Number of main pumps	NR	NR	NR
	➢ Jockey pump out put	NR	NR	NR
	➢ Jockey pump head	NR	NR	NR
	➢ Standby Pump out put	NR	NR	NR
	➢ Standby Pump Head	NR	NR	NR
	➢ Auto Staring/Manual stopping	NR	NR	NR
	➢ Pump House Access	NR	NR	NR
	• Terrace level			
	➢ Discharge of pump	450LPM	450LPM	MR
	➢ Head of the pump	40 MH	40 MH	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NR	NR	NR
	➢ Draw of connection	NR	NR	NR
	➢ Fire service inlet	NR	NR	NR
	➢ Access to tank	NR	NR	NR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➢ Pressurization of Lift Shaft	NR	NR	NR
	➢ Pressurization of lift lobby	NR	NR	NR
	➢ Communication in lift Car	NR	NR	NR
	➢ Fireman's Grounding Switch	NR	NR	NR
	➢ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➢ Total area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A
19.	Fire control room			
	➢ Detector system panel	N/A	N/A	N/A
	➢ Flow Switch Panel	N/A	N/A	N/A
	➢ PA System Panel	N/A	N/A	N/A
	➢ Battery backup	N/A	N/A	N/A
	➢ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Banquet/2016/WZ/936 dated 03/06/2016 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note: Owner of Premises has requested to change the address of Hotel / Banquet and letter for change of address from MCD is attached at C-28 & C-29.

12/6/19

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

D O (WD)

19/6/19

Dy. CFO (WZ)

21/6/19

CFO

21/06/19

FTPS