

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F.6/DFS/MS/School/WZ/2019/ 1348

Dated: 27/06/2019

FIRE SAFETY CERTIFICATE

Certified that the building of **Sarvodaya Vidyalaya, (School ID-1515004)** Located at, **East Punjabi Bagh, New Delhi**, comprised of 03 Blocks, BL-1=Ground Floor & BL-2 & 3= Ground + One Upper Floor Only, was issued FSC vide Letter No. F6/DFS/MS/School/2016/WZ/1370 dated-05/09/2016 for Ground Floor, The premises was re inspected by the officer concerned of this department on 17/06/2019 in the presence of Ms. Dr. Sadhana Agarwal (H.O.S) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the premises is fit for occupancy class " Educational" Group B with effect from 27/6/19 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on27/06/19... at New Delhi.


(Atul Garg)

Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal, Sarvodaya Vidyalaya, (School ID-1515004) East Punjabi Bagh, N. D.
2. Directorate of Education, Old Secretariat, Delhi - 110054.

Following fire safety directives must be adhered to:-

1. **The upper floor in block-2, having only one staircase strictly shall not be used for school activity.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.\

