

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6 DFS/MS/School/2019/SZ/ 1357

Dated: 27/6/19

FIRE SAFETY CERTIFICATE

Certified that the U.P. Project School located at Canal Colony ,Okhla, New Delhi -110025 comprised of ground floor only was issued NOC by this department vide letter No. F.6/DFS/MS/School/2016/ SZ/805 dated 19/05/2016. The premises was re-inspection by officer concerned by this department on 20/06/2019 in the presence of Mrs. Gaytari (Nodal Officer) of the school and found that fire prevention and fire safety requirements have deemed complied in accordance with Circular No. 262-362 dated 17/01/05 issued by Education Directorate, Govt. of NCT of Delhi, Old Secretariat, New Delhi and that the premises fit for occupancy class Education Building, Group-B as above with effect from the date of issue of this certificate for period of three years subject to compliance of conditions mentioned below.

Issued on 27/6/19 at New Delhi by

(Rajesh Panwar)
Dy. Chief Fire Officer
Tel. 011-26189168

Copy to: -

1. The Principal, U.P. Project School located at Canal Colony ,Okhla, New Delhi -110025
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.-110054

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

