

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No. F.6/DFS/MS/2019/Mall/SZ/1371

Dated: 2/7/19

FIRE SAFETY CERTIFICATE

Certified that M/s **MGF Metropolitan Mall** located at Plot No. A-2, District Centre, Saket, New Delhi -110017, comprised of two tiers basement, ground plus seven upper floors was issued FSC by this department vide letter No. F.6/DFS/MS/2015/Mall/SZ/2192 dated 17/12/2015. The premises was re-inspected by the officer concerned of this department on 15/06/2019 in the presence of Sh. Bhagat Ram Gola (Facility Manager) and observed that the fire safety norms as required under rule 33 of the Delhi Fire Service Rules, 2010 are deemed complied and that the building/premises is fit for occupancy class "**Mixed**" (Mercantile + Business) with effect from 2/7/2019 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 2/7/19 at New Delhi by


(Arul Garg)
Chief Fire Officer
Ph: 011-23414250

Copy to: -

1. The Authorized Signatory, M/s MGF Metropolitan Mall at Plot No. A-2 & P2A, District Centre, Saket, New Delhi -110017
2. The Executive Engineer (Bldg.), South Delhi Municipal Corporation, Green Park, Aurobindo Marg, New Delhi -110016

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

