

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2019/ 1367

Dated: 2/7/19

FIRE SAFETY CERTIFICATE

Certified that M/s Navin Bharti Preparatory School running on ground and first floor of the building comprised of ground plus two upper floors located at East Rohtas Nagar, Shahdara, Delhi-110032, owned/occupied by M/s Navin Bharti Preparatory School was issued FSC vide letter No. F6/DFS/MS/School/2016/NDZ/745 dated 11/05/16. The school building was re-inspected by the officer concerned of this department in the presence of Mr. R.M. Atrey, Manager of the school and found that the school building have complied with the fire prevention and fire safety requirements in accordance with Circular Letter No. F16/Estate/CC/Fire Safety/ 2011/3298 to 3398 dated-01/03/11 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 2/7/19.... for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....2/7/19.....at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer

01e
01e

To,
The Manager,
M/s Navin Bharti Preparatory School,
East Rohtas Nagar, Shhadara,
Delhi-110032

Copy:-
The Director of Education EDMC
Udyog Sadan, Plot No. 419, PIE,
Patparganj, Delhi-110092.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe évacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form `J` [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

