

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**



No. F6/DFS/MS/School/SZ/2019/ 1372

Dated: 02/07/19

FIRE SAFETY CERTIFICATE

Certified that **R.D. Rajpap Public School** located at Sector- 09, Dwarka, New Delhi- 110077, comprised of two blocks: Old Block comprise of ground plus three upper floors, New Block: basement, stilt, ground plus three upper floors was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2016/SZ/1006 dated 10.06.2016. The said school building was re-inspected by the officer concerned of this department on 29.06.2019 in the presence of Mrs. Vaishali Bhatnagar (Vice Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Services Rules, 2010 and that the building/premises is fit for occupancy class B "Educational Building", with effect from 02/07/19 for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 02/07/19 at New Delhi by.


(Rajesh Panwar)
Dy. Chief Fire Officer
Ph.01126179168


Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.
2. The Vice Principal, R.D. Rajpap Public School located at Sector- 09, Dwarka, New Delhi- 110077.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

