

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**


No.F6/DFS/MS/2019/ School/NDZ/ 1374


Dated:- 3/7/19

FIRE SAFETY CERTIFICATE

Certified that the **Victoria Girls Ser. Sec. School** located at **6, Rajpur Road, Delhi** comprises of **Ground + 01 Upper floor, School is running at ground floor only** was granted FSC by this department vide letter No. **F6/DFS/MS/School/NDZ/2016/196 dated 02/02/2016**. The premises was re-inspected by the officer concerned of this department on 02-04-2019 in the presence of Mrs. G.F. Sampson (Principal) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. B-I** with effect from ~~3/7/19~~ 2019 for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on 3/7/19 at New Delhi by.


(Sunil Chowshary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Principal,
Victoria Girls Ser. Sec. School,
6, Rajpur Road, Delhi.
2. Director of Education,
Old Secretariat, Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

