

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No.F.6/DFS/MS/School/2019/SZ /1386

Dated: 4/7/19

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidyalaya**, Chhawla, New Delhi-110071 comprised of three blocks namely Block-A, Block-B & Block-C. Block-A & Block-B having ground plus one upper floor and Block-C having ground floor only, owned occupied by Govt. of NCT of Delhi was issued FSC by this department vide letter no. F.6/DFS/MS/School/2016/SZ/581 dated 13.04.16. The school building was re-inspected by the officer concerned of this department on 24.06.2019 in the presence of Smt. Kiran Sharma (H.O.S) and found that Sarvodaya Kanya Vidyalaya have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....4/7/19..... at New Delhi.


(RAJESH PANWAR)
Dy. CHIEF FIRE OFFICER
SOUTH ZONE

Copy to:-

1. The Principal,
Sarvodaya Kanya Vidyalaya,
Chhawla, New Delhi-110071
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

7c
01/07/19

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.

