

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001



No. F.6/DFS/MS/Petl./2019/SZ/ 1384

Dated: 8/7/19

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Airport Service Station** (Retail Outlet of BPCL Petroleum Product) located at M.O.R Pocket Kalkaji, Opp. Nehru Place Bus Terminal, New Delhi-110019, comprised of ground floor only was issued FSC by this department vide letter No. F.6/DFS/MS/2015/SZ/879 dated 29/05/2015. The premise was re-inspected by officer concerned of this department on 24/06/2019 in the presence of Mr. Sanjay Sabharwal (Owner) of the filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Hazardous, Group-J**" (Filling Station) with effect from the date of issue of this certificate for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 8/7/19 at New Delhi by

  
(Atul Garg)  
Chief Fire Officer  
Ph: 011-23414250  


Copy to: -

1. M/s Airport Service Station (Retail Outlet of BPCL Petroleum Product) at M.O.R Pocket Kalkaji, Opp. Nehru Place Bus Terminal, New Delhi-110019
2. The Joint Commissioner of Police (Lic.), Ist Floor, P.S. Defence Colony, New Delhi-110049

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

