

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS; DELHI FIRE SERVICE, NEW DELHI-110001.**

No.F6/DFS/MS/Hospital/2019/SZ / 1390

Dated: 05/07/19

**FIRE SAFETY CERTIFICATE**

Certified that the Bensup Hospital located at Sector-12, Dwarka, New Delhi -110075, comprised of basement, Ground plus four upper floors, owned/occupied by B R Dhawan Cheritable Trust was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/Hospital/2006/1525 dated 7.7.2006. The said hospital building was re-inspected by the officer concerned of this department on 18.6.2019 in presence of Dr. Nirmal Dhawan (Owner) & Sh. Jitender (Representative) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the Building/premises is fit for occupancy class Group C "Institutional building" Sub-Division C-1 "Institutional Building" with effect from .....05/07/19..... for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on .....05/07/19..... at New Delhi by

  
(Atul Garg)

QC Chief Fire Officer  
Ph.011-23414250

Copy to:

1. The Joint Director, DDA, INA, Vikas Sadan, New Delhi.
2. The Authorized Signatory that the Bensup Hospital located at Sector-12, Dwarka, New Delhi 110075.

Recd  
Sip 05/07/19  
J. Lenecha Sigs  
mob. 8013235311

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. Access roads for movement of fire units in case of emergency all around the building shall be kept free from any hindrance.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

